



## NATIONAL CERTIFIED TESTING LABORATORIES

FIVE LEIGH DRIVE • YORK, PENNSYLVANIA 17406 • TELEPHONE (717) 846-1200  
FAX (717) 767-4100  
www.nctlinc.com

February 25, 2011

Mr. Yee Chi  
All Seasons Door & Window  
28 Edgeboro Road  
East Brunswick, NJ 08816

Dear Yee:

On February 24, 2011 tests were conducted by our laboratory on All Seasons Door & Window's Series "A-200" Double Hung Prime Window in accordance with the AAMA 1503 specification.

The specimen tested had a thermal transmittance (U-value) of 0.43 BTU/HR/FT<sup>2</sup>/°F and a Condensation Resistance Factor (CRF) of 56.

A full report containing the details of the above referenced test is forthcoming at the time of this letter. If you have any questions, please contact me at your convenience.

Sincerely,  
NATIONAL CERTIFIED TESTING LABORATORIES

  
DIGITAL SIGNATURE

STEVEN H. COBLE  
Simulation/ Thermal Department

SHC/amb  
Reference: NCTL-110-13602-1